



EMERGENCY BATTERY SYSTEM – REMOTE HEADS & ACCESSORIES



EBS1030 REMOTE HEADS WITH MOUNT (FACTORY SEALED)				CID1CD; C2D1EFG
10W 30VDC	PENDANT 3/4"①	CEILING 3/4"①	WALL 3/4"①	STANCHION 1-1/2"②
With Guard	EBS1030A2G	EBS1030X2G	EBS1030B2G	EBS1030D4G
Without Guard③	EBS1030A2	EBS1030X2	EBS1030B2	EBS1030D4

EBS1030 COMPONENTS & ACCESSORIES – DESCRIPTION	CATALOG NUMBER
EBS1030 10W 30V Head Only with LED's, Less Mount and Guard	EBS1030
Guard	EMG1
Red Guard – used to signify remote fixture is for Emergency	EMG1-R③
EXIT Accessory – 3-sided white painted aluminum	HEXA-100③
Dome Reflector	ERSD15
Angle Reflector	ERA15
Sealed Fittings Set for attachment of Pendant EBS1030 to EBS23HD-xxx	EBS-AHFS
Replacement Globe and Support Assembly	EMGS1



MOUNTING BOXES				
CATALOG NUMBER				HUB SIZE
PENDANT	CEILING	BRACKET	STANCHION	
EZA2	EZX2	EZB2	–	3/4"
EZA3	EZX3	EZB3	–	1"
–	–	–	EZD4②	1-1/4" / 1-1/2"

① For 1" pendant, ceiling and wall hubs, substitute "3" for "2" in catalog number; example: EBS1030A3G.

② Stanchion conduit hub size supplied is 1-1/2" with 1-1/2" to 1-1/4" reducer for 1-1/4" mounting.

③ Order fixture without guard for use with HEXA-100 EXIT Accessory, or to order EMG1-R Red Guard.

④ For EBS1030 with Mount Dimensions, see EMI15 series in lighting section.

EBSHK1030 10W 30V HEADS, COMPONENTS & ACCESSORIES		CID1BCD; C2D1EFG
DESCRIPTION	CATALOG NUMBER	
EBSHK Head Only with LED's – Requires Field Seal①	EBSHK1030	
EBSHK Head with ADJUSTABLE FACTORY SEALED "C" fittings set	EBSHK1030-RFSC	
EBSHK Head with ADJUSTABLE FACTORY SEALED "L" fittings set	EBSHK1030-RFSL	
Sealed Fittings Set for attachment of EBSHK to EBS23DH-xxx	EBS-AHFS	

① Seal purchased separately appropriate of area of use

EBS23DH SERIES ACCESSORIES – DESCRIPTION	CATALOG NUMBER
Remote Push-To-Test Station Group B 3/4" Feed-Thru w/Close Up Plug①	EBS-PTT
Remote Push-To-Test Station with Lock Off, Group B 3/4" Feed-Thru①	EBS-PTT-LO
Lock-Off for Integral Push-To-Test	G010502
Sealed Fittings Set for attachment of EBSHK to GEBC-2 or GEBL-2	EBS-AHFS
Replacement Battery Pack and Electronics	KLBP01
Replacement Vapor Capsule for corrosion protection	EBS-VC

① EBS23DH requires conduit seals (purchased separately) exiting enclosure within 18"; EBS-PTT contains a N.C. contact and is Factory Sealed for C&D and up to 5' for Group B.



EBS1030
Shown with
Exit Accessory



EBS1030



EMG1



EMG1-R



ERSD15



EMGS1



ERA15



EBSHK1030



EBSHK1030-RFSL



EBSHK1030-RFSC



EBS-PTT